

SULLIVAN COUNTY RURAL ELECTRIC COOPERATIVE, INC.

P.O. BOX 65, ROUTE 87
FORKSVILLE, PENNSYLVANIA 18616
(570) 924 - 3381 www.screc.com

INSTALLATION REQUIREMENTS FOR MAST TYPE SERVICE FOR PERMANENT BUILDINGS

IMPORTANT :

ALL INSTALLATIONS MUST BE INSPECTED AND APPROVED BY A RECOGNIZED INSPECTION AGENCY BEFORE THE SERVICE CAN BE ENERGIZED.

ALL INSTALLATIONS TO BE IN ACCORDANCE
WITH THE NATIONAL ELECTRICAL CODE

- A. MAINTAIN NOT LESS THAN 18 IN. VERTICAL CLEARANCE ABOVE ROOF
- B. MAINTAIN NOT LESS THAN 3 FT. VERTICAL CLEARANCE IN ACCORDANCE WITH NEC ARTICLE 230.24
- * TRIPLEX SERVICE DROP SHALL BE 19 FT. MINIMUM OVER PUBLIC AND PRIVATE THROUGHWAYS, DRIVEWAYS AND LAND TRAVERSED BY TRUCKS.
- * * MAST HIGHER THAN 3 FT. ABOVE ROOF REQUIRES GUYING.

